

DUCTWORK FOR REMOVAL OF GREASE AND SMOKE LADEN VAPORS

PART 1- GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Ductwork for removal of grease and smoke laden vapors.

1.2 REFERENCES

- A. Underwriters Laboratories (UL):
 - 1. UL1978 Test Standard -Grease Ducts for Restaurant Cooking Appliances.
- B. National Fire Protection Association (NFPA):
 - 1. NFPA 96 - Ventilation Control And Fire Protection Of Commercial Cooking Operations

1.3 QUALITY ASSURANCE

- A. Comply with NFPA 96 unless otherwise indicated.
- B. Must install duct in accordance to manufacturers listings and installation instructions.

1.4 WARRANTY

- A. Listed grease duct shall have a limited lifetime warranty to begin at the date of installation

PART 2- PRODUCTS

2.1 AVAILABLE MANUFACTURERS

- A. Listed Single-Wall non-insulated grease duct shall be model PSW manufactured by Metal-Fab, Inc.

2.2 LISTED DUCTWORK FOR REMOVAL OF GREASE AND SMOKE LADEN VAPORS

- A. The grease duct shall be non-insulated single-wall factory-built type for use with type I kitchen hoods, as described in NFPA-96 for the transportation of air and grease-laden vapors from commercial cooking operation.
- B. Product Description:
 - a. Metal-Fab Series PSW Grease Duct.
 - b. Factory prefabricated, single wall type, listed for venting of grease laden air from kitchen hoods requiring grease duct as described in NFPA 96.
 - c. Rated for continuous operation at 500 F and intermittent operation at 2000 F.
 - d. All components of the grease duct system shall be provided by the manufacturer to ensure the system meets the requirements of the listing including duct supports, guides, fittings, cleanouts, and expansion joints required to install the duct.
 - i. UL 1978 (File MH8251) - Grease Ducts for Restaurant Cooking Appliances.
 - e. The duct shall be constructed of 304 or 316 stainless steel, 0.035 inch thickness for sizes 6 to 36 inch diameters and 0.048 inch thickness for sizes 38 to 48 inch diameters. The duct assembly shall be tested and Listed to 18 inches clearance to combustibles in 6 to 48 inch diameters.
 - f. Model PSW shall be equivalent to welded steel duct for use within enclosed fire rated shafts at code prescribed clearances to fire rated shaft walls.

PART 3-EXECUTION

3.1 CONSTRUCTION OF FACTORY BUILT GREASE DUCT

- A. Pipe joints shall be held together by means of formed vee bands and sealed with P080 Grease Duct Sealant.
- B. Connection to the hood will be made with a round hood collar or a square-to-round transition.
- C. Curb mounted fans will incorporate a fan adaptor plate
- D. All construction and supporting of the kitchen ventilation system will be in accordance with Metal-Fab, Inc. installation instructions.
- E. Store grease duct sections inside or covered adequately to protect from weather or accidental damage.